

**Bruce-Grey Catholic District School Board**  
**Summary of Water Tests for Lead**  
**June 2008**

Location	Result per ug/L	ODWS*	Over/Under Limit
<b>Catholic Education Centre, Hanover - Standing Sample</b>	5.7	10	Under
<b>Catholic Education Centre, Hanover - Flushed Sample</b>	5.7	10	Under
<b>Mary Immaculate School, Chepstow- Standing Sample</b>	1.1	10	Under
<b>Mary Immaculate School, Chepstow - Flushed Sample</b>	1.5	10	Under
<b>St. Peter &amp; St. Paul's School, Durham - Standing Sample</b>	<1	10	Under
<b>St. Peter &amp; St. Paul's School, Durham - Flushed Sample</b>	<1	10	Under
<b>Immaculate Conception School, Formosa - Standing Sample</b>	5	10	Under
<b>Immaculate Conception School, Formosa - Flushed Sample</b>	2	10	Under
<b>Holy Family School, Hanover - Standing Sample</b>	<1	10	Under
<b>Holy Family School, Hanover - Flushed Sample</b>	<1	10	Under
<b>St. Anthony's School, Kincardine - Standing Sample</b>	1.1	10	Under
<b>St. Anthony's School, Kincardine - Flushed Sample</b>	<1	10	Under
<b>Sacred Heart Jr. School, Mildmay - Standing Sample</b>	1.8	10	Under
<b>Sacred Heart Jr. School, Mildmay - Flushed Sample</b>	<1	10	Under
<b>Sacred Heart Sr. School, Mildmay - Standing Sample</b>	1	10	Under
<b>Sacred Heart Sr. School, Mildmay - Flushed Sample</b>	<1	10	Under
<b>St. Basil's School, Owen Sound - Standing Sample</b>	1.6	10	Under
<b>St. Basil's School, Owen Sound - Flushed Sample</b>	4.1	10	Under
<b>Notre Dame School, Owen Sound - Standing Sample</b>	<1	10	Under
<b>Notre Dame School, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>Notre Dame Day Care, Owen Sound - Standing Sample</b>	<1	10	Under
<b>Notre Dame Day Care, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>St. Joseph's School, Port Elgin - Standing Sample</b>	1.9	10	Under
<b>St. Joseph's School, Port Elgin - Flushed Sample</b>	<1	10	Under
<b>Sacred Heart School, Teeswater - Standing Sample</b>	1.5	10	Under

<b>Sacred Heart School, Teeswater</b> - Flushed Sample	<1	10	Under
<b>Mother Teresa School, Walkerton</b> - Standing Sample	5.6	10	Under
<b>Mother Teresa School, Walkerton</b> - Flushed Sample	2.4	10	Under
<b>St. Mary's High School, Owen Sound</b> - Standing Sample	2.2	10	Under
<b>St. Mary's High School, Owen Sound</b> - Flushed Sample	1.1	10	Under
<b>SHHS, Walkerton</b> - Standing Sample	2.9	10	Under
<b>SHHS, Walkerton</b> - Flushed Sample	2	10	Under
<b>SHHS, Walkerton</b> - Standing Sample	<1	10	Under
<b>SHHS, Walkerton</b> - Flushed Sample	<1	10	Under

\* Ontario Drinking Water Standards