

Bruce-Grey Catholic District School Board
Summary of Water Tests for Lead
June 2009

Location	Result per ug/L	ODWS*	Over/Under Limit
Catholic Education Centre, Hanover - Standing Sample	<1	10	Under
Catholic Education Centre, Hanover - Flushed Sample	1.5	10	Under
Mary Immaculate School, Chepstow - Standing Sample	5.5	10	Under
Mary Immaculate School, Chepstow - Flushed Sample	4.3	10	Under
St. Peter & St. Paul's School, Durham - Standing Sample	3.5	10	Under
St. Peter & St. Paul's School, Durham - Flushed Sample	<1	10	Under
Immaculate Conception School, Formosa - Standing Sample	5.1	10	Under
Immaculate Conception School, Formosa - Flushed Sample	4.4	10	Under
Holy Family School, Hanover - Standing Sample	<1	10	Under
Holy Family School, Hanover - Flushed Sample	2.8	10	Under
St. Anthony's School, Kincardine - Standing Sample	<1	10	Under
St. Anthony's School, Kincardine - Flushed Sample	<1	10	Under
Sacred Heart Jr. School, Mildmay - Standing Sample	1.5	10	Under
Sacred Heart Jr. School, Mildmay - Flushed Sample	1.1	10	Under
Sacred Heart Sr. School, Mildmay - Standing Sample	<1	10	Under
Sacred Heart Sr. School, Mildmay - Flushed Sample	<1	10	Under
St. Basil's School, Owen Sound - Standing Sample	<1	10	Under
St. Basil's School, Owen Sound - Flushed Sample	1.2	10	Under
Notre Dame School, Owen Sound - Standing Sample	<1	10	Under
Notre Dame School, Owen Sound - Flushed Sample	<1	10	Under
Notre Dame Day Care, Owen Sound - Standing Sample	<1	10	Under
Notre Dame Day Care, Owen Sound - Flushed Sample	<1	10	Under
St. Joeseph's School, Port Elgin - Standing Sample	1	10	Under
St. Joeseph's School, Port Elgin - Flushed Sample	<1	10	Under
Sacred Heart School, Teeswater - Standing Sample	3.2	10	Under
Sacred Heart School, Teeswater - Flushed Sample	1.2	10	Under
Mother Teresa School, Walkerton - Standing Sample	6.1	10	Under

Mother Teresa School, Walkerton - Flushed Sample	3.2	10	Under
St. Mary's High School, Owen Sound - Standing Sample	1.8	10	Under
St. Mary's High School, Owen Sound - Flushed Sample	<1	10	Under
SHHS, Walkerton - Standing Sample	<1	10	Under
SHHS, Walkerton - Flushed Sample	<1	10	Under
SHHS, Walkerton - Standing Sample	2.2	10	Under
SHHS, Walkerton - Flushed Sample	1.8	10	Under

* Ontario Drinking Water Standards