

**Bruce-Grey Catholic District School Board  
Summary of Water Tests for Lead  
June 2007**

Location	Result per ug/L	ODWS*	Over/Under Limit
<b>Catholic Education Centre, Hanover - Standing Sample</b>	2	10	Under
<b>Catholic Education Centre, Hanover - Flushed Sample</b>	2	10	Under
<b>Mary Immaculate School, Chepstow- Standing Sample</b>	3	10	Under
<b>Mary Immaculate School, Chepstow - Flushed Sample</b>	2	10	Under
<b>St. Peter &amp; St. Paul's School, Durham - Standing Sample</b>	<1	10	Under
<b>St. Peter &amp; St. Paul's School, Durham - Flushed Sample</b>	<1	10	Under
<b>Immaculate Conception School, Formosa - Standing Sample</b>	<1	10	Under
<b>Immaculate Conception School, Formosa - Flushed Sample</b>	2	10	Under
<b>Holy Family School, Hanover - Standing Sample</b>	<1	10	Under
<b>Holy Family School, Hanover - Flushed Sample</b>	<1	10	Under
<b>St. Anthony's School, Kincardine - Standing Sample</b>	<1	10	Under
<b>St. Anthony's School, Kincardine - Flushed Sample</b>	2	10	Under
<b>Sacred Heart Jr. School, Mildmay - Standing Sample</b>	2	10	Under
<b>Sacred Heart Jr. School, Mildmay - Flushed Sample</b>	1	10	Under
<b>Sacred Heart Sr. School, Mildmay - Standing Sample</b>	<1	10	Under
<b>Sacred Heart Sr. School, Mildmay - Flushed Sample</b>	<1	10	Under
<b>St. Basil's School, Owen Sound - Standing Sample</b>	1	10	Under
<b>St. Basil's School, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>Notre Dame School, Owen Sound - Standing Sample</b>	<1	10	Under
<b>Notre Dame School, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>Notre Dame Day Care, Owen Sound - Standing Sample</b>	<1	10	Under
<b>Notre Dame Day Care, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>St. Joseph's School, Port Elgin - Standing Sample</b>	3	10	Under
<b>St. Joseph's School, Port Elgin - Flushed Sample</b>	2	10	Under
<b>Sacred Heart School, Teeswater - Standing Sample</b>	2	10	Under

<b>Sacred Heart School, Teeswater - Flushed Sample</b>	3	10	Under
<b>Mother Teresa School, Walkerton - Standing Sample</b>	4	10	Under
<b>Mother Teresa School, Walkerton - Flushed Sample</b>	1	10	Under
<b>St. Mary's High School, Owen Sound - Standing Sample</b>	<1	10	Under
<b>St. Mary's High School, Owen Sound - Flushed Sample</b>	<1	10	Under
<b>SHHS, Walkerton - Standing Sample</b>	<1	10	Under
<b>SHHS, Walkerton - Flushed Sample</b>	<1	10	Under

\* Ontario Drinking Water Standards