

# Bruce-Grey Catholic District School

## Board Audit - 2003

**Building name: Sacred Heart School**

**Location: 18 Gordon St., Teeswater**

**Assessment by: Chris MacCready**

**Date: Monday August 25, 2003**

**Total number of students: 101**

**Number of students living with a disability?**

**Deaf/Hard of hearing 1**

**Blind/Low vision 0**

**Physical 1**

**Developmental 0**

**Number of employees living with a disability?**

**Deaf/Hard of hearing 0**

**Blind/Low vision 0**

**Physical 0**

**Developmental 0**

**Number of community events that occupy the school annually?**

**Number of persons with a disability that live with a disability in your community?**

**Deaf/Hard of hearing**

**Blind/Low vision**

**Physical**

**Developmental**

**Notes: The school secretary showed me around the building.  
Overall, this school rates 2 (moderately accessible).**

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Building Approach &amp; Entrance</b>						
1 - Wheelchair parking spot(s)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
- Upright wheelchair parking signs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
- Each spot 2400mm (95") wide plus 1500mm (60") side access?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
- Located near accessible entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
- Located on firm level surface?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
2 - Curb ramp to front door						
- Maximum slope 1:12 ratio	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
- Is it a barrier-free path on a firm, slip resistant surface?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
3 - Are there ramps and curb cuts at other appropriate doors? (e.g. JK door, alternate bus door, portables)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
4 - Transition at ramp < 13mm (1/2")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
5 - Railing on ramp?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
6 - Non-slip surface on ramp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<b>Entrance Doors</b>						
7 - Threshold < 13mm (1/2")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
- Door width at least 860mm (34")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
8 - Automatic entrance doors?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
9 - Good location & timing of button?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
10 - Signage for button						
- Is the door clearly marked with the international access symbol?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
<b>Exterior and Fire Doors</b>						
11 - Do they operate smoothly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
12 - Is the spring load set at the appropriate strength?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<p>Suggestions:</p> <ul style="list-style-type: none"> <li>- Mark and sign one accessible parking spot near main entrance.</li> <li>- Install ramps at all alternate doors.</li> </ul>						

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Stairwells</b>						
13 - Non-slip treads?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
14 - Railings on both sides of staircase and landings?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
15 - Adequate lighting?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Suggestions:						
School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Hallways</b>						
16 - 2.44 - 3.66m (8-12 ft.) wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
17 - Free of obstructions? (i.e. any horizontal projections more than 100mm (4") that start above 680mm (2'3"))	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
18 - Circle mirrors for blind corners?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
19 - Doorways > 860mm (34") wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
20 - Wheelchair turnaround room 1500mm (5')?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
Suggestions:						

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Portables</b>						
21 - Doorways > 860mm (34") wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
22 - Threshold < 13mm (½")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
23 - Landing large enough to allow for wheelchair entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
24 - P.A. System?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>

Suggestions:

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Gymnasium</b>						
<b>Change Room</b>						
25 - Accessible to washroom fixtures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
26 - Accessible to clothing storage (i.e. hooks, lockers)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
27 - Accessible to shower ?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
<b>Stage</b>						
28 - Handrails on both sides of stairs?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
29 - Ramps (correct ratio) or lift?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
30 - Adequate lighting?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>

Suggestions:

- Install a portable ramp to the stage as needed.

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Library Pits</b>						
31 - handrail?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
32 - ramps –max. slope 1:12?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
33 - adequate lighting?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
34 - visual contrast at top step?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
35 - Adequate space around shelves?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
36 - Security gates / turnstiles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<b>Library Facilities</b>						
37 - check out / return counter?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
38 - photocopier?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
39 - computers?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
40 - study tables?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>

Suggestions:

- Install a lower library check out counter or a cut out to provide wheelchair access.

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Elevator/Lift</b>						
41 - Location - near exit? - Clear door width > 910 mm (36")?	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>		<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
42 - close to washroom?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
43 - Key access at wheelchair height?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
44 - Delayed door closure?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
45 - Alarm button/phone?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>

Suggestions:

School Area	Existing		Accessible		Notes / Required Modifications	Not Applicable
	Yes	No	Yes	No		
<b>Wheelchair Accessible Washroom</b>						
46 - Wheelchair accessible stalls on each floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
47 - 1.5m (5ft.) turnaround room in stall?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<b>Appropriate fixtures:</b>						
48 - Wheelchair toilet 450mm (18")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
49 - Sink with lever handles or infrared sensor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Short lever handles	<input type="checkbox"/>
50 - Paper towel rack and/or air dryer?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
51 - Soap dispenser at appropriate height and manageable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
52 - Wheelchair accessible sink with 680mm (2'3") knee space?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Not enough knee space	<input type="checkbox"/>
53 - Mirror at 1m (3'3")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Too high	<input type="checkbox"/>
54 - Grab bar on dividing wall? - 750mm (2'5") to 850mm (2'8") height? - > 1.04 m (3'5") beside the toilet to allow for a lateral transfer?	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input type="checkbox"/>	Diagonal grab bar	<input type="checkbox"/> <input type="checkbox"/>
55 - Grab bar on wall behind toilet?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
56 - Door position, spring & swing out hinges allow for wheelchair entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
57 - Alarm button by toilet?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
58 - Hot water temperature < 50°C (120°F)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<p>Suggestions: - Upgrade accessible washrooms to current CSA standard.</p>						

School Area	Existing		Accessible		Requires Modification	Not Applicable
	Yes	No	Yes	No		
<b>Classrooms</b>						
59 - Lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
60 - Knob handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<b>Wheelchair Accessible</b>						
61 - Computer Lab?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
62 - Science Labs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
63 - Photography?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
64 - Tech. Shops?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
65 - Kitchens?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>
66 - Space to move about classroom?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<b>Classroom equipment accessible</b>						
67 - pencil sharpener?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
68 - sinks?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
69 - desks?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
70 - shelves?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
71 - computers?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
72 - personal belonging storage?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
73 - gathering area?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
74 - chalk boards?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
75 - Light switches <1220mm (48")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
76 - Fire alarm pull station, <1220mm (48")?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>

Suggestions:

- Upgrade door knobs with lever handles as they are replaced.
- Install accessible sinks in classrooms as they are replaced.

School Area	Existing		Accessible		Requires Modification	Not Applicable
	Yes	No	Yes	No		
<b>Health/Special Needs Change Room</b>						
77 - 860mm (34") clear dooropening?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
78 - Wall mounted change table?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
79 - Privacy curtain?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
80 - Storage area and turnaround room for Hoyer Lift or ceiling lift?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
81 - Locked storage for supplies?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
82 - 1.5m (5ft.) turnaround room?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
83 - Wheelchair accessible sink?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
84 - Hot water temperature < 50°C (120°F)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
85 - Alarm Buzzer to main office?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
86 - Access door lockable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
Suggestions:						

School Area	Existing		Accessible		Requires Modification	Not Applicable
	Yes	No	Yes	No		
<b>Office/Work Room Accessible</b>						
87 - filing cabinets?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
88 - photocopier?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
89 - work station?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
90 - P.A. system?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
91 - door width – 34” (860mm)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
92 - passageways – 34” (860mm)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
93 - washroom?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Suggestions: - Provide staff with access to accessible washroom as needed.						
School Area	Existing		Accessible		Requires Modification	Not Applicable
	Yes	No	Yes	No		
<b>Staff Room Accessible?</b>						
94 - door width – 34” (860mm)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
95 - furniture i.e. table, phone, bulletin board?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
96 - kitchen sink?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
97 - appliances?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
98 - mail boxes?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
Suggestions: - Provide staff with accessible appliances as needed.						

## **Additional Information**

99. Does the building have an accessible telephone? No
100. Is a TTY phone available for persons with hearing impairments? No
101. Does the facility include any tactile signage or detectable warning systems for persons with visual impairments? No

## **Suggestions/Recommendations:**

- **Mark and sign one accessible parking spot near main entrance.**
- **Install ramps at all alternate doors.**
- **Install a portable ramp to the stage as needed.**
- **Install a lower library check out counter or a cut out to provide wheelchair access.**
- **Upgrade accessible washrooms to current CSA standard.**
- **Upgrade door knobs with lever handles as they are replaced.**
- **Install accessible sinks in classrooms as they are replaced.**
- **Provide staff with access to accessible washroom as needed.**
- **Provide staff with accessible appliances as needed.**